


FIELD

REMOTE I/O


MCC BUCKET

PANEL

CAKE PUMP
WATER INJECTION
VALVE




120VAC




RIO-10
RACK 2
SLOT 5
LINE 70822

WET CAKE MATERIAL BIN
SLIDE GATE #1



120VAC


120VAC




RIO-10
RACK 2
SLOT 4
LINE 70722

LINE 70724

CAKE PUMP
DISCHARGE
PRESSURE




24VDC, 4-20mA




RIO-10
RACK 3
SLOT 4
LINE 71407

16+

CAKE PUMP
STATOR
TEMPERATURE



24VDC, 4-20mA



RIO-10
RACK 3
SLOT 1
LINE 71203

6+

TAG	DESCRIPTION	MANUFACTURER	MODEL NO.	CALIBRATION
EV-16.1.1	SOLENOID VALVE 1/2" NC	ASCO	EF8210G94	X
ZSC-16.1.1	POSITION SWITCH	X	X	X
ZSO-16.1.1	POSITION SWITCH	X	X	X
PT-16.4.1	PRESSURE TRANSDUCER	ENDRESS & HAUSER	PMC45-PC11S6H1BF1	0-300 psi
TT-16.4.1	TEMPERATURE TRANSMITTER	ROSEMOUNT	3144D1ES	0-300°F
TT-16.4.1	MOUNTING BRACKET	ROSEMOUNT	03044-2131-001 PIPE	

RELEASED 12/08/06
REVISION - 0



DATE:	3/18/06
DATE:	
DATE:	
FILE:	1524E1824
SCALE:	NONE
SIZE:	
REV	0
FOR FINAL REVIEW/BUILDING PERMIT	
REVISION	
DATE	12/08/06

CITY OF STAMFORD CONNECTICUT
SOLIDS DRYING PROJECT
PELLETIZING TRAIN GROUP 016
LOOP DIAGRAM
PROJECT NUMBER 1524
DRAWING NUMBER EI-824
SHEET 2 OF 2