

1

2

3

4

5

6


FIELD

REMOTE I/O


MCC BUCKET

PANEL


CONDENSER  
PLANT WATER  
SUPPLY



CONDENSER  
PLANT WATER  
PRESSURE



CONDENSER  
HIGH LEVEL



RIO-10  
PANEL TB

CR70811

CB70219

RIO-10  
PANEL TB

LINE 70216


RIO-10  
RACK 2  
SLOT 5  
LINE 70811

RIO-10  
RACK 2  
SLOT 3  
LINE 70634

RIO-10  
RACK 2  
SLOT 4  
LINE 70732



ANDRITZ-RUTHNER, INC.  
1010 COMMERCIAL BLVD. SOUTH  
ARLINGTON, TEXAS 76001  
(817) 465-5611




DATE:	3/21/06
DRAWN BY:	BB
CHECKED BY:	
APPROVED BY:	
SCALE:	NONE
SIZE:	1524E1851
PROJECT NUMBER:	1524
TITLE:	PELLETIZING TRAIN GROUP 500 LOOP DIAGRAM
JOB NAME:	CITY OF STAMFORD CONNECTICUT SOLIDS DRYING PROJECT
REV:	0
DATE:	12/08/06
REVISION:	FOR FINAL REVIEW/BUILDING PERMIT

DDS40

TAG	DESCRIPTION	MANUFACTURER	MODEL NO.	CALIBRATION
PSL-500.1.1	PRESSURE SWITCH LOW	NEO-DYN	132P58C3G 30P W/SEAL	X
EV-500.1.1	SOLENOID VALVE 6"	KEystone	920 W/ACT	X
LSH-500.1.1	LEVEL SWITCH HIGH	X	X	X

THIS DRAWING IS COPY RIGHTED  
FOR HIS PERSONAL USE WITHOUT THE SIGNED WRITTEN CONSENT OF ANDRITZ-RUTHNER, INC., IT MUST NOT BE COPIED NOR MADE AVAILABLE TO THIRD PARTIES, INCLUDING COMPETITORS, NOR MADE ACCESSIBLE TO SUCH PARTIES. ANY ILLEGAL USE BY THE RECEIVER OR THIRD PARTIES FOR WHICH HE IS RESPONSIBLE CAN CONSTITUTE A CAUSE FOR LEGAL ACTION. THIS DRAWING MUST BE RETURNED ON REQUEST OF THE COMPANY.

RELEASED 12/08/06  
REVISION-0



DRAWING NUMBER: EI-851  
SHEET 2 OF 2