


FIELD

REMOTE I/O


MCC BUCKET

PANEL

CAKE TRANSFER CONVEYOR MOTOR




460V/3PH/60HZ




EP-402

CAKE TRANSFER CONVEYOR ZERO SPEED




120VAC

PLC-10 PANEL TB




PLC-10 RACK 1 SLOT 4 LINE EP-70522

CAKE TRANSFER VALVE




120VAC

PLC-10 PANEL TB




PLC-10 RACK 1 SLOT 5 LINE EP-70601

CAKE TRANSFER VALVE POSITION




120VAC

PLC-10 PANEL TB




PLC-10 RACK 1 SLOT 4 LINE EP-70513




120VAC

PLC-10 PANEL TB



LINE EP-70515




REV	DATE	DESCRIPTION
0	12/08/06	FOR FINAL REVIEW/BUILDING PERMIT
1	05/11/06	ADDED ZSO, ZSC & EV 611.1.1 TO PLC-10 I/O

DATE:	3/21/06
CHECKED BY:	BB
APPROVED BY:	
SCALE:	NONE
SIZE:	1524E1855

JOB NAME: CITY OF STAMFORD CONNECTICUT SOLIDS DRYING PROJECT
 TITLE: PELLETIZING TRAIN GROUP 611 LOOP DIAGRAM
 PROJECT NUMBER: 1524
 DRAWING NUMBER: EI-855
 SHEET 1 OF 1

TAG	DESCRIPTION	MANUFACTURER	MODEL NO.	CALIBRATION
M-611.1.1	MOTOR	X	X	X
SSL-611.1.1	ZERO SPEED SWITCH	TELEMECANIQUE	XSAV-11801	
EV-611.1.1	SOLENOID VALVE	X	X	
ZSO-611.1.1	POSITION SWITCH OPEN	X	X	
ZSC-611.1.1	POSITION SWITCH CLOSED	X	X	

RELEASED 12/08/06
 REVISION - 0



THIS DRAWING IS COPY RIGHTED AND IS THE PROPERTY OF ANDRITZ-RUTHNER, INC. IT IS TO BE USED ONLY FOR THE PROJECT AND SITE SPECIFICALLY IDENTIFIED IN THE TITLE. ANY REUSE, REPRODUCTION, OR MODIFICATION OF THIS DRAWING WITHOUT THE WRITTEN CONSENT OF ANDRITZ-RUTHNER, INC. IS STRICTLY PROHIBITED. ANDRITZ-RUTHNER, INC. WILL BE RESPONSIBLE FOR ANY DAMAGE TO PROPERTY OR PERSONS CAUSED BY THE USE OF THIS DRAWING.