



**INSTALLATION NOTES:**

1. EQUIPMENT CONNECTION JOINTS TO BE GASKETED.
2. GASKETS & HARDWARE PROVIDED BY ANDRITZ.
3. CONTRACTOR TO PROVIDE FILED DIMENSIONS REQUIRED FOR CHUTES AFTER EQUIPMENT IS INSTALLED.

TAG EQP'T 40.006.000



ROTIARY VALVE (006) SHIPPED LOOSE FOR FIELD INSTALLATION (WEIGHT 675 LBS) GASKETED & BOLTED CONNECTION TOP & BOTTOM

EL. 39.88'

EL. 11.33'

ELEVATION VIEW

THIS DRAWING IS COPY RIGHTED AND IS A TRADE SECRET AND ONLY ENTRUSTED TO THE RECEIVER FOR HIS PERSONAL USE WITHOUT THE SIGNED WRITTEN CONSENT OF ANDRITZ-RUTHNER, INC. IT MUST NOT BE COPIED NOR MADE AVAILABLE TO THIRD PARTIES, INCLUDING COMPETITORS, NOR MADE ACCESSIBLE TO SUCH PARTIES. ANY LEGAL USE BY THE RECEIVER OR THIRD PARTIES FOR WHICH HE IS RESPONSIBLE CAN CONSTITUTE A CAUSE FOR LEGAL ACTION. THIS DRAWING MUST BE RETURNED ON REQUEST OF THE COMPANY.



DATE:	12/20/05	DATE:	01/17/07
DRAWN BY:	JEN	DATE:	06/05/06
CHECKED BY:		DATE:	
APPROVED BY:		DATE:	
SCALE:	3/8"=1'-0"	FILE:	152400620
SIZE:			
PROJECT NUMBER:	DDS40	REV:	0
TITLE:	ROTARY AIR LOCK (006) INSTALLATION & UTILITIES	REV:	1
JOB NAME:	CITY OF STAMFORD CONNECTICUT SOLIDS DRYING PROJECT	REV:	0
PROJECT NUMBER:	1524	REV:	1
DRAWING NUMBER:	006-20	REV:	1
SHEET:	1 OF 1		

CITY OF STAMFORD CONNECTICUT  
 SOLIDS DRYING PROJECT  
 ROTARY AIR LOCK (006)  
 INSTALLATION & UTILITIES