




- NOTES:
- EXISTING BREAKER IN CELL 3C IS DESIGNATED FOR FEEDING THE SOLIDS DRYER MCC, PROVIDED BY ANDRITZ. PROVIDE AND CONNECT FEEDER CONDUCTORS BETWEEN THIS BREAKER AND THE SOLIDS DRYER MCC. PROVIDE NEW NAMEPLATE ON BREAKER DOOR TO READ "FEEDER SOLIDS DRYER MCC". NAMEPLATE TO MATCH EXISTING
 - PROVIDE A NEW 480V, 3PH, 200A FEEDER BREAKER AND DOOR IN EXISTING SPACE IN UNIT 8J IN THE EXISTING MCC TO FEED THE ASD FOR THE ODOR CONTROL EXHAUST FAN EF-153-4. PROVIDE AND CONNECT FEEDER CONDUCTORS BETWEEN THIS BREAKER AND THE ASD. PROVIDE NEW NAMEPLATE ON UNIT DOOR TO READ "ODOR CONTROL EXHAUST FAN EF153-4". UNIT DOOR COLOR AND NAMPLATE TO MATCH EXISTING. EXISTING MCC IS CUTLER HAMMER FREEDOM 2100, C.O. # MPG00143-067



A
B
C
D

1 2 3 4 5 6

THESE RECORD DOCUMENTS HAVE BEEN PREPARED BASED ON THE INFORMATION PROVIDED BY OTHERS. THE DESIGN PROFESSIONAL HAS NOT VERIFIED THE ACCURACY AND/OR COMPLETENESS OF THIS INFORMATION AND SHALL NOT BE RESPONSIBLE FOR ANY ERRORS OR OMISSIONS WHICH MAY BE INCORPORATED HEREIN AS A RESULT.

	STAMFORD WATER POLLUTION CONTROL AUTHORITY SOLIDS DRYING PROJECT	CH2MHILL ELECTRICAL SITE PLAN	RECORD DRAWING RE-ISSUED FOR CONSTRUCTION ISSUED FOR CONSTRUCTION FOR FINAL REVIEW/ BUILDING PERMIT	N CLERK D DOAR B GACKSTATTER
			NO. DATE 3 01/20/08 2 09/09/06 1 07/04/06 0 06/05/06	DR N DATOO D DOAR B GACKSTATTER
VERIFY SCALE BAR IS ONE INCH ON ORIGINAL DRAWING.		DATE JUNE 2006 PROJ 334058 DWG E-2400 SHEET E2		